

SN 2022/46 - Battery units 9A0100.12 and 9A0100.14 no longer available

Exported from Confluence on 2022 October 06

Table of Contents

SN 2022/46 - Battery units 9A0100.12 and 9A0100.14 no longer available3

Battery units 9A0100.12 and 9A0100.14 no longer available 3

Possible replacement with 9A0100.16 4

SN 2022/46 - Battery units 9A0100.12 and 9A0100.14 no longer available

Key Information

Sales Notice Number	SN 2022/46
Creation Date	04 Oct 2022
Last Modified Date	06 Oct 2022
Author(s)	Herbert Wimmer
Sales Notice Type	Product-related
Portfolio Line	Industrial PCs and Panels
Quicklinks	
Status	VALID
Confidentiality	GLOBAL



9A0100.12



9A0100.14



9A0100.16

Battery units 9A0100.12 and 9A0100.14 no longer available

In SN 21/2021 we have informed about the discontinuation of the battery packs 9A0100.13, 9A0100.15 and 9A0100.17. Due to increased shipping restrictions and an incompatibility in wiring, we had recommended to use the battery units 9A0100.12, 9A0100.14 or 9A0100.16 as replacement/spare parts instead of battery packs.

The battery units had initially been discontinued together with the UPS. As the installed batteries were discontinued too, but still available, we withdrew the discontinuations of the battery units.

Now the manufacturer Panasonic has informed on short notice, that the 7.2 Ah and 2.2 Ah batteries (used in 9A0100.12 and 9A0100.14) are no longer available anymore. Therefore we are forced to inform, that the battery units 9A0100.12 and 9A0100.14 are also no longer available anymore. The last shipment phase is already over, therefore no additional orders can be placed anyway.

- 9A0100.12 UPS Battery Unit A 24V 7.2Ah **NOT AVAILABLE ANYMORE**
- 9A0100.14 UPS Battery Unit B 24V 2.2Ah **NOT AVAILABLE ANYMORE**



Possible replacement with 9A0100.16

The battery unit 9A0100.16 is still available, so in case of an replacement we recommend switching to this battery unit.

With regard to the battery capacity, the battery unit 9A0100.16 with 4.5 Ah would allow to fully replace battery units 9A0100.14 with 2.2 Ah. Despite the lower battery capacity compared to the battery unit 9A0100.12 with 7.2 Ah, we recommend switching to the battery unit 9A0100.16 here as well. Please take care, that a lower battery capacity could have an impact on UPS buffering and shutdown times.

- 9A0100.16 UPS Battery Unit C 24V 4.5Ah



9A0100.16

Please keep in mind, that changes of the battery type have to be configured in the UPS configuration software and programmed to the UPS unit too. Only with that it can be ensured that charging the battery will work properly.
